

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**



**LISTING No.** 3266-0057:105

Page 1 of 1

**CATEGORY:** Door Operators

**LISTEE:** Stanley, 65 Scott Swamp Road, Farmington, CT 06032  
Contact: Ismael Agasino (860) 679-6453 Fax (860) 679-6409

**DESIGN:** Model MAGIC-FORCE pedestrian swing door operator for commercial and industrial use. Unit is electro-mechanical power operated. Door is opened by a permanent magnet dc motor when energized by \*the door controller. Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, rating, and UL label.

**APPROVAL:** Listed as a door operator for swinging doors used on \*3 hr fire-rated doors and assemblies. Authority having jurisdiction should be consulted prior to installation.

\*Rev. 01-12-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 13, 2009**

*Listing Expires June 30, 2010*

Authorized By: **FRANCIS MATEO**, Program Coordinator  
Fire Engineering Division